



SIJIL PERAKUAN BAHAN
CERTIFICATE OF MATERIAL APPROVAL

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakui bahawa
Fire and Rescue Department of Malaysia
hereby certify that

PM2 BUILDING SYSTEM SDN BHD (1071828-W)
No.19 Jalan SB Indah 1/18,
Taman Sg. Besi Indah,
43300 Seri Kembangan,
Selangor DE.


Bagi bahan binaan / pemasangan keselamatan kebakaran
For building material / fire safety equipment

DRYWALL CONSTRUCTION

Berdasarkan piawaian
As complying with

BS 476:PART 22:1987

Tempoh sah perakuan: **07/07/2014 hingga 06/07/2015**


(DATO' MAHADI BIN MD. ALI)
Timbalan Ketua Pengarah (Operasi),
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: **7** Julai 2014

No. Fail: JBPM/IP/BKK:700-7/2/9-457 (3)
No.Siri: BB/DD/1884/2014

LAMPIRAN A1

Jenis Bahan Binaan	:	COMPOSITE WALL PANEL 1 JAM (NON-LOADBEARING)
Jenama & Spesifikasi	:	'PM2' COMPOSITE WALL PANEL (POLYSTYRENE CORE - 150mm thickness)
Nama & Alamat Pengeluar	:	PM2 BUILDING SYSTEM SDN BHD Lot 5930 Kawasan Perusahaan Kamunting, 34600 Kamunting. Perak DR.
Tahap Rintangan Api	:	INTEGRITI 130 MINIT & INSULASI 113 MINIT
No. Laporan ujian/Tarikh	:	SIRIM 2014FE0151 (06/05/2014)
Skim Persijilan Barangan	:	-----
Had Kegunaan	:	TIDAK DIBENARKAN PENGGUNAAN SEBAGAI 'PARTY WALL'. PEMASANGAN HENDAKLAH MEMATUHI SPESIFIKASI UJIAN, UBBL 1984 SERTA SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 & A3.



Tempoh sah perakuan: **07/07/2014 hingga 06/07/2015**